



July 7, 2020

Infrastructure Fund Issuer
 Enex Infrastructure Investment Corporation
 Keiichi Matsuzuka, Executive Officer
 (Securities Code: 9286)
 Asset Management Company
 Enex Asset Management Co., Ltd.
 Keiichi Matsuzuka, Representative Director,
 President and CEO
 Inquiries: Keisuke Hioki, Director and General Manager of
 Finance & General Accounting Department
 TEL: +81-3-4233-8330

Monthly Power Generation and Output Curtailment at Assets Under Management (June 2020)

Enex Infrastructure Investment Corporation (hereinafter “EII”) announces the actual amount of power generation and output curtailment for June 2020 for the power generation facilities it owns as of June 30, 2020, as follows.

1. Monthly Power Generation (3rd fiscal period: December 1, 2019, to November 30, 2020)

Fiscal period ending November 30, 2020					
	No. of properties	Solar module output (kW)	Forecast power generation (kWh) (Note 1) (A)	Actual power generation (kWh) (B)	Difference (kWh) (B)-(A)
December 2019	5	37,628.68	2,690,259	1,998,036	(692,223)
January 2020 (Note 2)	6	40,289.80	3,039,931	2,433,206	(606,725)
February 2020	6	40,289.80	3,444,929	3,394,818	(50,111)
March 2020	6	40,289.80	4,477,739	4,103,184	(374,555)
April 2020	6	40,289.80	4,774,701	4,962,262	187,561
May 2020	6	40,289.80	4,870,993	4,662,425	(208,568)
June 2020	6	40,289.80	4,110,095	4,117,172	7,077
July 2020	—	—	—	—	—
August 2020	—	—	—	—	—
September 2020	—	—	—	—	—
October 2020	—	—	—	—	—
November 2020	—	—	—	—	—
Total	—	—	—	—	—

(Note 1) Forecast power generation (P50) refers to the power generation output calculated by the producer of technical reports or other experts, as a figure of an exceedance probability P (percentile) 50 (a numerical value deemed achievable with a 50% probability). (hereinafter, “forecast power generation (P50)”)

(Note 2) EII acquired a property in Nagasaki Kinkai on January 17, 2020. Accordingly, the number of properties increased to 6 and solar module output, forecast power generation, and actual power generation came to include the property.

2. Monthly Power Generation by Power Plant

June 2020					
Property No.	Property name	Solar module output (kW)	Forecast power generation (kWh) (A)	Actual power generation (kWh) (B) (Note 3)	Difference (kWh) (B)-(A)
S-01	Takahagi Solar Power Plant	11,544.00	1,059,263	1,191,312	132,049
S-02	Chiyoda Kogen Solar Power Plant	1,595.28	160,865	169,752	8,887
S-03	JEN Hofu Solar Power Plant	1,940.64	208,125	231,816	23,691
S-04	JEN Kusu Solar Power Plant	1,007.76	99,732	105,468	5,736
S-05	Hokota Solar Power Plant	21,541.00	2,324,315	2,158,440	(165,875)
S-06	Nagasaki Kinkai Solar Power Plant	2,661.12	257,795	260,384	2,589
	Total	40,289.80	4,110,095	4,117,172	7,077

(Note 3) “Actual power generation” is based on the data on meter reading slips of electric utilities, however, the values for Kusu and Nagasaki Kinkai are based on the available data on power generation.

3. Implementation of Output Curtailment

In June 2020, no curtailment was implemented at renewable energy power generation facilities.

*EII website: <https://enexinfra.com/en>